



VIRTUE<sup>SAL</sup>

Grow by Virtue of Efficiency

# Analysis and Evaluation Sheet

## Aircosaver Version 4.1

### Company Name

DALFA  
BEIRUT

### Unit Information from nameplate

Make: Line Voltage: 2 220 V  
Phasing: SINGLE

### Installation Address :

DINA'S OFFICE

Tonnage or BTU : 12 TH. Btu Power: 0.9 KW

### 22 HRS Test Without Aircosaver

Beg.Date and Time Tuesday 10 April 18:00  
End Date and Time Wednesday 11 April 2012 16:00

### 22 HRS Test With Aircosaver

Beg.Date and Time Wednesday 11 April 18:00  
End Date and Time Thursday 12 April 2012 16:00

### Thermostat set Point

Setting Inside 18 Degree Celsius

### Thermostat set Point

Setting Inside 18 Degree Celsius

### Inside Temperature

Average 19.82 Celsius

### Inside Temperature

Average 19.00 Celsius

### Power Consumption (KWH)

10.82 KWH

### Power Consumption (KWH)

7.89 KWH

**Saving in KWH**

2.94 KWH

**Saving %**

27%

Data Collected FROM ENISCOPE- MAC 001BE51023A8 ON April 12 16:30

Report Prepared on : April 12 , 2012

### Witness by Company :

Name: Dina Awada  
Position: Accounting Director  
Date: 12/4/2012  
Signature: [Signature]

### Witness by VIRTUE S.A.L. :

Name: Amr Badr  
Position: Managing Director  
Date: Apr. 12, 2012  
Signature: [Signature]