

DATE: November 20, 2012

TEST NO: 1

### COMPANY DETAILS:

Company Name: Bank Islami  
Contact Person: Mr. Salman-ur-Rehman  
Designation: Operations Manager  
Address: 8C-A & 9D-A, Commercial Area Phase II, DHA, Karachi  
Contact Details: (021)- 111-BIP-111 (111-247-111)

### INSTALLATION DETAILS:

Make: Dawlance  
Type: Wall Mount Split  
Capacity: 02 Ton  
Line Voltage: 220 V, Single Phase  
Location: Office Hall

### TEST RESULTS

#### Without AircoSaver

	Date	Time	Temp	Units
Start	19-Nov	12:56	22°C	163.577
Stop	19-Nov	15:52	22°C	166.193
Total		2:56		02.616

Units Consumed per Hour: 0.8918


#### With AircoSaver

	Date	Time	Temp	Units
Start	20-Nov	13:15	22°C	171.512
Stop	20-Nov	16:15	22°C	173.445
Total		3:00		01.933

Units Consumed per Hour: 0.6443

SAVINGS in KWH: 0.2475

SAVINGS in %: 27.75%

  
**SALMAN UR REHMAN**  
Customer Services Manager  
Bank Islami Pakistan Limited  
DHA Phase II Br. (1050) Karachi

---

CLIENT ACKNOWLEDGEMENT

  
22/11/12

---

FOR ENERTECH