

DATE: November 20, 2012

TEST NO: 3

COMPANY DETAILS:

Company Name: Bank Islami
Contact Person: Mr. Salman-ur-Rehman
Designation: Operations Manager
Address: 8C-A & 9D-A, Commercial Area Phase II, DHA, Karachi
Contact Details: (021)- 111-BIP-111 (111-247-111)

INSTALLATION DETAILS:

Make: Dawlance
Type: Wall Mount Split
Capacity: 02 Ton
Line Voltage: 220 V, Single Phase
Location: ATM Room

TEST RESULTS

Without AircoSaver

	Date	Time	Temp	Units
Start	19-Nov	13:39	22°C	579.626
Stop	19-Nov	15:51	22°C	581.508
Total		2:12		1.882

Units Consumed per Hour: 0.854


With AircoSaver

	Date	Time	Temp	Units
Start	20-Nov	14:20	22°C	591.397
Stop	20-Nov	16:32	22°C	592.696
Total		2:12		1.299

Units Consumed per Hour: 0.5904

SAVINGS in KWH: 0.2649

SAVINGS in %: 30.97%


SALMAN UR REHMAN
Operations Manager
Bank Islami Services Limited
Bank Islami Pakistan Limited
DHA Phase-II B.I. Karachi

CLIENT ACKNOWLEDGEMENT


20/11/12

FOR ENERTECH