

DATE: January 3, 2013
TEST NO: 2

COMPANY DETAILS:

Company Name: Master Showroom - Master Group
Contact Person: Mr. Mehmood; Mr. Rizwan
Designation: Chief Engineer; Showroom Incharge
Address: 26th Street, DHA Phase V, Karachi
Contact Details:

INSTALLATION DETAILS:

Make: General
Type: Wall Mount Split
Capacity: 2.5 Ton
Line Voltage: 220 V, Single Phase
Location: Office Hall

TEST RESULTS

Without AircoSaver

	Date	Time	Temp	Units
Start	2-Jan	16:08	18°C	682.845
Stop	2-Jan	19:22	18°C	689.379
Total		03:14		6.534

Units Consumed per Hour: 2.02 KWH

With AircoSaver

	Date	Time	Temp	Units
Start	3-Jan	15:40	18°C	689.440
Stop	3-Jan	19:05	18°C	694.085
Total		03:05		4.645

Units Consumed per Hour: 1.339

SAVINGS in KWH: 0.681

SAVINGS in %: 33.75%

CLIENT ACKNOWLEDGEMENT

FOR ENERTECH