

Dominos AircoSaver Test Store 6711 - 3022 Thousand Oaks, San Antonio, TX 78247

Airco was installed on Jun 20, 2008
at the end of the May/Jun 2008
billing cycle. (Data included for
comparison only)

	May/Jun 2008			May/Jun 2007			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	13280	30	442,7	13200	33	400,0	42,7	9,6%
Mean temperature daily average	86			79			7	8,1%

	Jun/Jul 2008			Jun/Jul 2007			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	13040	33	395,2	13200	32	412,5	-17,3	-4,4%
Mean temperature daily average	85			80			5	5,9%

	Jul/Aug 2008			Jul/Aug 2007			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	11280	29	389,0	12720	29	438,6	-49,6	-12,8%
Mean temperature daily average	85			83			2	2,4%

	Aug/Sep 2008			Aug/Sep 2007			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	10800	30	360,0	13000	31	419,4	-59,4	-16,5%
Mean temperature daily average	82			82			0	0,0%

	Sep/Oct 2008			Sep/Oct 2007			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	10520	32	328,8	11640	28	415,7	-87,0	-26,5%
Mean temperature daily average	76			80			-4	-5,3%

	Oct/Nov 2008			Oct/Nov 2007			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	7560	27	280,0	10880	32	340,0	-60,0	-21,4%
Mean temperature daily average	65			68			-3	-4,6%

	Nov/Dec 2008			Nov/Dec 2007			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	6840	29	235,9	8680	29	299,3	-63,4	-26,9%
Mean temperature daily average	56			58			-2	-3,6%

	Dec/Jan '08-'09			Dec/Jan '07-'08			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	8520	36	236,7	9560	35	273,1	-36,5	-15,4%
Mean temperature daily average	60			58			2	3,3%

	Jan/Feb '09			Jan/Feb '08			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	7400	29	255,2	8520	29	293,8	-38,6	-15,1%
Mean temperature daily average	60			58			2	3,3%

	Feb/Mar '09			Feb/Mar '08			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	7680	29	264,8	9760	29	336,6	-71,7	-27,1%
Mean temperature daily average	64			63			1	1,6%

	Mar/Apr '09			Mar/Apr '08			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	8920	31	287,7	10160	29	350,3	-62,6	-21,8%
Mean temperature daily average	68			69			-1	-1,5%

	Apr/May '09			Apr/May '08			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	9.440	29	325,5	12.600	32	393,8	-68,2	-21,0%
Mean temperature daily average	79			76			3	3,8%

	May/Jun '09			May/Jun '08			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	11.040	31	356,1	13.280	30	442,7	-86,5	-24,3%
Mean temperature daily average	82			86			-4	-4,9%

	After Airco			Before Airco			daily KWh difference	% change
	T KWh	days	daily KWh	T KWh	days	daily KWh		
	9.420	30	310	11.167	30	368	-58	-19,4%
Mean temperature daily average	66,0			65,8			0,2	0,3%

