

▣

AircoSaver Trial Report

Life Healthcare St
Georges Hospital

17 August 2010 (Ref 1002)

AIRCOSAVER

The air conditioner monitored by meter with serial number 30531633 was monitored from Tuesday 25 May 2010 at 13h58 until Tuesday, 1 June 2010 at 13h30 without an AircoSaver

The AircoSaver was installed on the same air conditioner (as above) and monitored by meter with serial number 30531633 from Tuesday, 27 July 2010 at 10h30 until Sunday, 1 August 2010 at 12h00

RESULTS

Specification	Without AircoSaver	With AircoSaver
Start date and Time	Thursday, 27 May 2010 15h00	Thursday, 29 July 2010 15h00
End date and Time	Friday, 28 May 2010 17h00	Friday, 30 July 2010 17h00
Total kWh	7.713 kWh (average 0.145)	4.599 kWh (average 0.086)
Average saving		40.3%

Specification	Without AircoSaver	With AircoSaver
Start date and Time	Tuesday, 25 May 2010 15h00	Tuesday, 27 July 2010 15h00
End date and Time	Friday, 28 May 2010 17h00	Friday, 30 July 2010 17h00
Total kWh	25.866 kWh (average 0.173)	11.507 kWh (average 0.0772)
Average saving		55.5%
