

DATE: December 4, 2012
TEST NO: 1

COMPANY DETAILS:

Company Name: Darul Sehat Hospital
Contact Person: Mr. Umair
Designation: Maintenance Head
Address: Block 15, Gulistan-e-Jauhar Karachi
Contact Details:

INSTALLATION DETAILS:

Make: Mitsubishi
Type: Split
Capacity: 1.5 Ton
Line Voltage: 220 V, Single Phase

TEST RESULTS

Without AircoSaver

	Date	Time	Temp	Units
Start	30-Nov	12:31 PM	22 C	670.750
Stop	30-Nov	3:33 PM	22 C	676.755
Total		3:00		6.185

Units Consumed per Hour: 2.039

With AircoSaver


	Date	Time	Temp	Units
Start	4-Dec	12:53 PM	22 C	677.627
Stop	4-Dec	3:57 PM	22 C	682.462
Total		3:03		4.835

Units Consumed per Hour: 1.585

SAVINGS in KWH: 0.453

SAVINGS in %: 22.25%

He conduct Demo his self and set all the reading with himself


4/12/2012



CLIENT ACKNOWLEDGEMENT
Engr. Umair Ahmed Khan
HOD Maintenance & Operations
LCMD & Darul Sehat Hospital

FOR ENERTECH