

DATE: July 18, 2012

TEST NO: 1

COMPANY DETAILS:

Company Name: Wiltrans Cargo Services
Contact Person: Mr. Aatif Barlas
Designation: Manager Customer Support
Address: Berth # 12, East Wharf KPT, Karachi,
Contact Details: 0092-21-35873189-91

INSTALLATION DETAILS:

Make: Haier
Type: Split
Capacity: 2 Ton
Line Voltage: 220 V, Single Phase

TEST RESULTS

Without AircoSaver

| | Date | Time | Temp | Units |
|-------|--------|-----------|------|---------|
| Start | 13-Jul | 12:55 PM | 24C | 287.856 |
| Stop | 13-Jul | 5:55 PM | 24C | 300.534 |
| Total | | 05:00 Hrs | | 12.678 |

Units Consumed per Hour: 2.536

With AircoSaver

| | Date | Time | Temp | Units |
|-------|--------|-----------|------|---------|
| Start | 13-Jul | 7:30 AM | 24C | 277.62 |
| Stop | 13-Jul | 12:30 PM | 24C | 287.856 |
| Total | | 05:00 Hrs | | 10.236 |

Units Consumed per Hour: 2.047

SAVINGS in KWH: 0.488 per Hour

SAVINGS in %: 19.28%



CLIENT ACKNOWLEDGEMENT



FOR ENERTECH