

DATE: November 12, 2012
TEST NO: 02

COMPANY DETAILS:

Company Name: Workforce Software
Contact Person: Mr. Abbas Paliwala
Designation: Operations Manager
Address: 101, Business Center, Main Sharah-e-Faisal, Karachi
Contact Details: 92-21-34324323-4

INSTALLATION DETAILS:

Make: Mitsubishi Heavy Industries
Type: Split
Capacity: 1.5 Ton
Line Voltage: 220 V, Single Phase

TEST RESULTS

Without AircoSaver

	Date	Time	Temp	Units
Start	2-Nov	3:20 PM	26C	120.5
Stop	2-Nov	6:20 PM	26C	124.55
Total		3:00 Hr		4.05

Units Consumed per Hour: 1.35

With AircoSaver

	Date	Time	Temp	Units
Start	5-Nov	8:11 PM	26C	139.549
Stop	5-Nov	10:19 PM	26C	141.258
Total		2:08 Hr		1.709

Units Consumed per Hour: 0.801

SAVINGS in KWH: 0.5489 KWH/Hr

SAVINGS in %: 40.65%

Workforce Software Development
(Private) Limited
Abbas Al
Chief Executive/Director

CLIENT ACKNOWLEDGEMENT

19-Nov-2012

FOR ENERTECH